



Office of Statewide Health Planning and Development



**Facilities Development Division**  
400 R Street, Suite 200  
Sacramento, California 95811-6213  
(916) 440-8300  
Fax (916) 324-9188  
[www.oshpd.ca.gov/fdd](http://www.oshpd.ca.gov/fdd)

August 26, 2008

Mr. Richard Lloyd  
Mason Industries  
2101 W. Crescent Ave. Suite D  
Anaheim, CA 92801

Subject: Mason Seismic Restraint Guidelines for Suspended Piping, Ductwork And Electrical Systems  
OPA-0349

Dear Mr Lloyd:

Mason Industries' Seismic Restraint Guidelines (OPA-0349) remains an acceptable reference for California Hospital Projects. Should you wish to confirm this information, please contact the writer by phone at: 916-440-8470 or via e-mail at: [tpike@oshpd.ca.gov](mailto:tpike@oshpd.ca.gov).

Sincerely,

A handwritten signature in black ink that reads 'Anthony R. Pike'. The signature is written in a cursive, flowing style.

Anthony R. Pike  
Senior Structural Engineer

cc: File

# Memorandum

State of California



*"Equitable Healthcare Accessibility for California"*

---

**To:** All FDD Staff

**Date:** April 22, 2008

**From:** John D. Gillengerten, S.E.  
Deputy Director

**Subject:** 2007 CBC and Use of Existing Pre-Approvals

Until further notice, existing OSHPD anchorage pre-approvals (OPA) may be used on projects subject to the 2007 California Building Code (CBC) without modification. All aspects of the design and installation of the pre-approved component or system, including computation of the lateral forces, shall be in accordance with the approved OPA.